

NPDES Testing and Reporting Guidelines

Effluent Characteristics			Discharge Limitations		Monitoring Requirements	
Reporting			Concentration		Measurement Frequency	Sample Type
Reporting Code	Units	Parameter	30 day	Daily		
00056	GPD	Flow	-	-	1/year	
00530	mg/L	Total Suspended Solids	-		1/year	Grab
00610	mg/L	Nitrogen, Ammonia				
		(summer)	-	2.0	1/year	Grab
		(winter)	-	4.5	1/year	Grab
80082	mg/L	CBOD ₅	-	15	1/year	Grab
31616	#/100ml	Fecal Coliform (summer)	-	2000	1/year	Grab
00083	-	color, severity	-	-	1/year	Estimate
01330	-	odor, severity	-	-	1/year	Estimate
01335	-	Turbidity, severity	-	-	1/year	Estimate
00300	mg/L	Dissolved Oxygen	Not less than 6.0 at any time		1/year	Grab
50060	mg/L	Chlorine, total residual	Not to exceed 0.038 at any time		1/year	Grab

Medina County Health Department
 Environmental Health Division
 4800 Ledgewood Drive
 Medina, Ohio 44256
 (330) 723-9523
 (888) 723-9688 (toll free)

